

- (7) Cooling of a TIER-2 BESS shall not use groundwater other than for closed-loop geothermal cooling. The application shall include a description of the proposed cooling system of the TIER-2 BESS.